

## COPY OF WATER TESTING REPORT

### REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtlsangrur@gmail.com

To,

Modern International Convent School  
Ladal (Sangrur)

No.: RWTL/SNG/2526/00119      Dated : 10/05/2025

Subject :      Testing Reports of Water Samples.


Reference:      Your Letter/SRF No. MICS-2025/GEN      Dated: 06/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 07/05/2025. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A :      Test Report



Authorized Signatory  
For, Regional Water Testing Lab  
Sangrur



**REGIONAL WATER TESTING LAB, SANGRUR**  
Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur  
rwtlsangrur@gmail.com

TEST REPORT						
Name & Address of Customer : <b>Modern International Convent School Ladal (Sangrur)</b>			Customer Reference No.		No : MICS-2025/GEN Dated : 06/05/2025	
			Sample Submitted by			
			Date of Sample Receipt		07/05/2025	
			Analysis Starting Date		08/05/2025	
			Analysis completion Date		10/05/2025	
Discipline : <b>Chemical Testing, Bacteriological Testing</b>			Group: <b>Water</b>			
ULR No.:			Sample Type :		Water	
Test Report No.:		<b>RWTL/SNG/2526/00119</b>	Date of Issue :		10/05/2025	
Registration no.:		<b>RWTL/SNG/REG2526/00340</b>	Condition of Sample :		Unsealed	
Collection Point:		<b>Treatment Plant (RO/CWPP/ARP/HH Purifier)</b>	Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:		<b>Not Mentioned(Not Mentioned)</b>	Location/Depth :		R.O / NA	
Village :		<b>Not Mentioned</b>	Habitation :		Not Mentioned	
Block:		<b>Not Mentioned</b>	District :		Sangrur	
Latitude :		<b>Not Mentioned</b>	Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Iron(Fe)	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
2	Sulphate(SO4)	8	200	400	mg/l	Spectrophotometric Method
3	Fluoride(F)	BDL(0.05)	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed. 2017)/IS-3025 (Part-60)
4	Nitrate(NO3)	BDL(0.5)	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3-(23rd Ed. 2017)
5	Arsenic(As)	BDL(0.005)	0.01	No relaxation	mg/l	Spectrophotometric Method/ Colorimetric Method
6	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
7	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

*[Signature]*

**Dr. Ramesh Jhorar**  
Quality Manager  
Authorized Signatory  
For, Regional Water Testing Lab  
Sangrur

----- End of the Test Report -----

Page No : 1/1

